

Table 1. Groundwater Sample Results

Substance	Result	MCL¹	SMCL²
General Chemistry			
Alkalinity	300 mg/L	n/a ³	n/a
Chloride	1.7 mg/L	n/a	250 mg/L
Sulfate	14 mg/L	n/a	250 mg/L
pH	7	n/a	6.5-8.5
Metals and Minerals			
Barium	140 ug/L	2000 ug/L	n/a
Calcium	58 mg/L	n/a	n/a
Copper	1.1 ug/L	1300 ug/L	n/a
Iron	0.06 mg/L	n/a	0.3 mg/L
Magnesium	37 mg/L	n/a	n/a
Nickel	1 ug/L	n/a	100 ug/L
Potassium	0.81 mg/L	n/a	n/a
Silicon	6.6 mg/L	n/a	n/a
Sodium	3.9 mg/L	n/a	20 mg/L
Strontium	0.76 mg/L	n/a	4000 ug/L
Zinc	21 ug/L	n/a	5000 ug/L

¹ Maximum Contaminant Level

² Secondary Maximum Contaminant Level

³n/a indicates that contaminant levels not established by the EPA.